



Ref. Certif. No.

SE-86031

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Hybrid power unit, eSite x10
Name and address of the applicant	Flexenclosure Dubbogatan 2, 534 50 Vara, SWEDEN
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Flextronics International GmbH Niederlassung Althofen, Friesacher Strasse 3, A-9330 Althofen AUSTRIA
Ratings and principal characteristics	Input AC: 220-240V, 3x16A, 50Hz, Class I Input DC: 125V, Max 60A Output DC: 40-58V, Max. 250A
Trademark (if any)	<i>flexenclosure</i>
Customer's Testing Facility (CTF) Stage used	CTF Stage 1
Model / Type Ref.	RSY-001/1
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 60950-1:2005+A1+A2 (EN 60950-1:2006+A11+A1+A12+A2)
As shown in the Test Report Ref. No. which forms part of this Certificate	1612756STO-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 17 February 2017

Intertek

Signature:

Bo Berglöv

Additional information (if necessary)

Common Modifications and Special national Conditions for CENELEC countries have been checked.

A sample of the product was tested and found to be in conformity with:

IEC 60950-22 :2005 and EN 60950-22:2006+A11:2008. Refer to Intertek Semko AB test report 1612756STO-002

IEC 60529:1989+A1:1999+A2:2013 and EN 60529:1991+A1:2000+A2:2013. Refer to Intertek Semko AB test report 1612794STO-002

END

Date: 17 February 2017

Signature: 